

Great Lakes Gas Transmission Company

Tentative Schedule of Planned Maintenance

Friday, January 27, 2012 to Monday, March 12, 2012

Start	End	Station	Unit	Description
11/28	2/6	(None)	(None)	This Mode will not be available until the Separator is tie
12/5	2/10	(None)	(None)	Clow-Turbine Meter M72 Certification [Run 1]
1/3	3/16	GLG 13 - Otisville	Otisville - 01	1301 Power Turbine Major Overhaul
1/17	2/1	GLG 02 - Thief Riv	Thief River - 01	RegROUT of unit 201
2/1	2/1	GLG 13 - Otisville	Otisville - 02	1302- Vibration Monitoring System M24 Inspection, Air
2/7	2/7	GLG 07 - Wakefiel	(None)	Overpressure Equipment DOT M12 Inspection
2/7	2/8	GLG 13 - Otisville	Otisville - 03	1303- GG LM1600 GG H6K Borescope and Inspection
2/8	2/8	GLG 02 - Thief Riv	(None)	Overpressure Equipment DOT M12 Inspection
2/8	2/24	(None)	(None)	Section 5 ILI Digs (50% pressure reduction and shut-in
2/9	2/9	GLG 01 - St. Vince	(None)	Overpressure Equipment DOT M12 Inspection □ Valve
2/15	2/15	GLG 03 - Shelvin	(None)	Overpressure Equipment DOT M12 Inspection
2/16	2/16	GLG 05 - Cloquet	(None)	Overpressure Equipment DOT M12 Inspection
2/21	2/21	GLG 06 - Iron River	(None)	Overpressure Equipment DOT M12 Inspection
2/23	2/23	GLG 04 - Deer Riv	(None)	Unit Recycle Valve M12 Inspection (Unit 401) □ Unit Re
2/28	2/29	GLG 01 - St. Vince	St. Vincent - 04	Power Cylinder Inspections

Note: Daily throughput restrictions relating to scheduled maintenance are dependent on actual operating conditions on the pipeline.

Friday, January 27, 2012