

Great Lakes Gas Transmission Company

Tentative Schedule of Planned Maintenance

Monday, July 05, 2010 to Friday, July 23, 2010

Unit / CS	Start Date	Online Date	7/5/2010			7/12/2010			7/19/2010			Project Description	
			Mon	Wed	Fri	Mon	Wed	Fri	Mon	Wed	Fri		
105	7/6/2010	7/7/2010		X								Air Intake M12 Plenum, Unit Recycle Valve M12 Inspections (8 Hr)	
301	7/7/2010	7/8/2010			X							Soakwask & Air Intake M12 Plenum Inspection (6 Hrs)	
502	7/7/2010	7/8/2010			X							Air Intake M12 Plenum Inspection (4 Hrs)	
1101	7/8/2010	7/9/2010			X							Repair	
303	7/8/2010	7/9/2010			X							Soakwask & Unit Recycle Valve M12 Inspection (8 Hrs)	
101	7/8/2010	7/9/2010			X							Recip Jacket Water Cooler M12 Inspection	
802	7/8/2010	7/9/2010			X							Soakwash Inspection	
102	7/9/2010	7/10/2010			X							Recip Jacket Water Cooler M12 Inspection	
1000	7/12/2010	7/13/2010					X					Battery Charger Capacitor Replacement (4 Hrs)	
104	7/12/2010	7/17/2010					X	X	X	X	X	Miscellaneous Repairs	
503	7/13/2010	7/14/2010					X					Soakwask & Air Intake M12 Plenum Inspection (8 Hrs)	
1002	7/13/2010	7/14/2010					X					Avon Soakwash and Inspection (4 Hrs)	
1001	7/13/2010	7/14/2010					X					Avon Soakwash and Inspection (4 Hrs)	
1201	7/13/2010	7/14/2010					X					Spark Plug H3K Replacement (4 Hrs)	
10A00	7/14/2010	7/15/2010						X				Valve and Valve Operator M12 Leak Inspection / Cycle Test (8 Hr)	
10A00	7/14/2010	7/15/2010						X				Emergency Shutdown System M12 Inspection (8 Hrs)	
301	7/15/2010	7/16/2010						X				Minor Overhaul (8 Hrs)	
1301	7/19/2010	7/24/2010								X	X	X	Dry Seal Replacement
801	7/20/2010	7/21/2010								X			Borescope Inspection (6 Hrs)
1100	7/20/2010	8/15/2010								X	X	X	Station Modifications
303	7/20/2010	7/21/2010								X			Air Intake M12 Plenum and Borescope Inspections (8 Hrs)

Note: Daily throughput restrictions relating to scheduled maintenance are dependent on actual operating conditions on the pipeline.

Tuesday, July 06, 2010

Unit / CS	Start Date	Online Date	7/5/2010			7/12/2010			7/19/2010			Project Description	
			Mon	Wed	Fri	Mon	Wed	Fri	Mon	Wed	Fri		
402	7/21/2010	7/22/2010										X	Chip Detector Replacement
1001	7/22/2010	7/23/2010										X	PT Minor Overhaul (8 Hrs)
501	7/22/2010	7/23/2010										X	Borescope & Air Intake M12 Plenum Inspection (6 Hrs)
803	7/22/2010	7/23/2010										X	GE Abrasive Wash and Inspection (8 Hrs)

Note: Daily throughput restrictions relating to scheduled maintenance are dependent on actual operating conditions on the pipeline.